

FAFNIR ATG Details

Station Name

System Type

wired wireless

Tank Components

- VISY-Stick Standard (also for Biodiesel / E10 / Ethanol)
- VISY-Stick Advanced (also for Biodiesel / Ethanol)
- VISY-Stick N for urea solution (AdBlue®)
- VISY-Stick Flex (also for Biodiesel / E10)
- VISY-Stick LPG
- VISY-Density
- VISY-Stick Interstitial Dry / Wet
- VISY-Reed Interstitial Dry / Wet
- VISY-Stick Sump Manhole
- VISY-Reed Sump Manhole

Dispenser Components

- VISY-Stick Sump Dispenser
- VISY-Reed Sump Dispenser

Date of Installation

Date of Commissioning

Warranty Start

Warranty End

Date

Signature (Installer)

Date

Signature (Station Manager / Project Manager)

Terminal No. (VP-Board)	Tank No. / Dispenser No.	Tank Volume	Tank Diameter	Type of Product	Offset (see Offset Diagram)	VISY-Stick Ser. No.	VISY-Stick Density Ser. No.	VISY-Stick Interstitial Ser. No.	VISY-Reed Interstitial Ser. No.	VISY-Stick Sump Manhole Ser. No.	VISY-Reed Sump Manhole Ser. No.	VISY-Stick Sump Dispenser Ser. No.	VISY-Reed Sump Dispenser Ser. No.
1													
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													

Offset Diagram

Offset = vertical distance (b) + safety distance

The vertical distance (b) can be read out from the drawing below.

The safety distance is a mounting distance to the tank bottom and should be 10 mm.

